WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

In Book

OFFICE USE ONLY
Log No. 59607
Permit No.
Basin 212

1. OWNER Kenneth Stokley ADDRESS 8185 S. LA CIENEGA

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 22 S N/S R. 61 E. CLARK County
PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☑ Recondition ☐	Domestic ☑ Irrigation ☐ Test ☐	Cable ☐ Rotary ☑
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL + SAND		0	10	
CALICHE		10	13	
CLAY		13	180	
SLUFFING GRAVEL		180	200	
WATER	160			
"	170			
"	185			
"	198			

RECEIVED
MAR 24 1980
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started Mar 13, 19 80
Date completed Mar 16, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 11 in inches Total depth 200 feet
Casing record
Weight per foot Thickness 10 gua

Diameter	From	To
8 5/8 inches	+1 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 ft. feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation TORCH-CUT
Size perforation 1/8" x 16" x STAGGERED
From 200 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 95 Feet below land surface 93
Flow G.P.M.
Water temperature WARM °F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES A. DIMICK
Address 4375 W. Tioga
Nevada contractor's license number 10062
Nevada driller's license number 995
Signed Charles A. Dimick
Date Mar. 20, 1980

USE ADDITIONAL SHEETS IF NECESSARY

O-627