

Log No. 59658  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1980

PRINT OR TYPE ONLY

1. OWNER Richard Frerri ADDRESS AT WELL LOCATION SandHill & Quendo  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 NW 1/4 Sec. 31 T. 21 N/S R. 62 E CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	150	150
CEMENT GRAVEL		150	200	50
BROWN CLAY		200	271	71
FRIST WATER	43			
MAIN WATER	265			

8. WELL CONSTRUCTION  
 Diameter hole 12 1/4 inches Total depth 271 feet  
 Casing record 8 & 5/8  
 Weight per foot 11.5 Thickness 156  
 Diameter 8 & 5/8 inches From 0 feet To 271 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 271 feet to 50 feet  
 Perforations:  
 Type perforation FACTORY  
 Size perforation 16 PER FT  
 From 251 feet to 131 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 NOV 28 1984  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 11-20, 1984  
 Date completed 11-26, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Flow 47 G.P.M. 0 P.S.I.  
 Water temperature 66 ° F. Quality GOOD

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name VEGAS DRILLING CO. Contractor  
 Address 5956 Calvert Contractor  
 Nevada contractor's license number 015972  
 Nevada contractor's drillers number 944  
 Nevada driller's license number 944 Actual Driller  
 Signed [Signature] Contractor  
 Date 11-27-84

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

SECRET

CONFIDENTIAL