

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"OD	0	150	150	Cemented from 0 to 50 feet 3 yards of pea gravel 2 yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.
Well Driller

By A. F. Effinger
License No. 212

Dated October 20, 1955

(Not to be filled in by Driller)
