WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59674
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5035

1. OWNER Myron Heaton
MAILING ADDRESS 3920 East Patrick Lane
Las Vegas, Nevada

ADDRESS AT WELL LOCATION Same

2. LOCATION SE SW ¼ NE ¼ Sec. 31 T. 21 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sandy clay		0	15	15
grey clay		15	20	5
grey clay	x	20	35	15
brown sandy clay		35	50	15
gravel	x	50	51	1
brown sandy clay		51	53	2
green clay		53	75	22
brown sandy clay		75	88	13
gravel		88	90	5
graveley clay		90	115	25
graveley clay	xx	115	170	55
graveley clay		170	184	14
gravel	xx	184	190	6
graveley clay	xxx	190	230	40
brown sticky clay		230	250	20

RECEIVED
OCT 12 1990
Div. of Water Resources
Branch Office - Las Vegas, Nev.

Date started 9-12-90, 19
Date completed 9-26-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Bailed	40 G.P.M. from 87 ft.		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 250 feet
inches
inches
Casing record
Weight per foot .188 8" & 6" Thickness

Diameter	From	To
12" Hole inches	0 feet	80 feet
8" Casing inches	0 feet	122 feet
6" Casing inches	115 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 80 ft feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation XXX Torch cut
Size perforation 3/16" X 10"
From 116 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 22 ft. feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S. R. McKinney & Sons, Inc. (Contractor)
Address 1042 South Main St. Las Vegas, Nevada (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 2065
Nevada contractor's driller's number issued by the Division of Water Resources 45
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 270
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-5-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

[illegible]		22	5	0	22
[illegible]		[illegible]	2	0	11
[illegible]		[illegible]	1	0	6
[illegible]		12	1	1	11
[illegible]		11	12	0	55
[illegible]		[illegible]	11	2	25
[illegible]					13
[illegible]		3	7	22	
[illegible]		1	5	2	
[illegible]		2	3	1	15
[illegible]		2	3	1	15
[illegible]		1	2	0	11
[illegible]		1	1	0	11