

OFFICE USE ONLY
Log No. 59714
Permit No.
Basin. 212

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER P. Klas ADDRESS 1675 Desert Inn Rd.
Las Vegas, Nevada
2. LOCATION SE 1/4 NE 1/4 Sec. 11 T. 22 N/S R. 61 E Clark County
PERMIT NO.

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sandy Clay		0	4	4
Caliche		4.5	5	1
Brown Clay		5	30	25
Brown Clay	XX	30	40	10
Red Clay		40	45	5
Brown Clay		45	70	25
Brown Clay	XX	70	90	20
Brown Clay Gravel	XX	90	108	18
Brown Sandy Clay Gravel		108	148	40
Brown Sandy Clay Gravel	XX	108	152	4
Brown Sandy Clay		152	175	23
Brown Sandy Clay Gravel	XX	175	185	10
Brown Sandy Clay Gravel		185	200	15

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 200 feet
Casing record.
Weight per foot 10 gauge Thickness.
Diameter From To
12 inches 0 feet 50 feet
10 inches 50 feet 200 feet
Surface seal: Yes No Type cement
Depth of seal 50 Ft. feet
Gravel packed: Yes No
Gravel packed from feet to feet
Perforations:
Type perforation torch cut
Size perforation 3/16"x12" 4 rows
From 50 feet to 200 feet

Date started Jan. 27, 1970, 19
Date completed Jan. 30, 1970, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
			1 hr.

9. WATER LEVEL
Static water level 30 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S.R. McKinney & Sons. Inc.
Address 1042 E. Main St., Las Vegas, Nev
Nevada contractor's license number 2065
Nevada driller's license number 45
Signed [Signature]
Date 8-31-70

BAILER TEST

G.P.M.	Draw down	feet	hours