

OFFICE USE ONLY  
 Log No. 59739  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Earl Peters ADDRESS Las Vegas, Nevada.

2. LOCATION NE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 31 T. 21 N/S R. 62 E. Clark County  
 PERMIT NO. \_\_\_\_\_

|   |  |   |
|---|--|---|
| 3. TYPE OF WORK   | 4. PROPOSED USE  | 5. TYPE WELL  |
| New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> | Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> | Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> |
| Deepen <input type="checkbox"/> Other <input type="checkbox"/>                    | Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>          | Other <input type="checkbox"/>  |

6. LITHOLOGIC LOG

| Material                                  | Water Strata | From | To  | Thick-ness |
|---|--------------|------|-----|------------|
| Top soil                                  |              | 0    | 2   | 2          |
| Clay                                      |              | 2    | 32  | 30         |
| Tight lime                                |              | 32   | 41  | 9          |
| Clay                                      |              | 41   | 48  | 7          |
| Clay with sand and gravel                 | 48           | 48   | 58  | 10         |
| Red clay                                  |              | 58   | 92  | 34         |
| Clay with sand and gravel                 |              | 92   | 92  | 34         |
| gravel                                    | 92           | 92   | 123 | 31         |
| Sand and gravel with stringers of redclay | 123          | 123  | 200 | 77         |

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 200 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 13# Thickness 135  
 Diameter 8 5/8" From 0 feet To 200 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cemented  
 Depth of seal 88 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Vertical slot  
 Size perforation 1/4" x 7"  
 From 140 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**

NOV 16 1976

Div. of Water Resources  
 Branch Office — Las Vegas, Nev.

Date started 11/1, 1976  
 Date completed 11/7, 1976

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
|        |           |      |       |
|        |           |      |       |
|        |           |      |       |

9. WATER LEVEL

Static water level 15 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature 68 ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WEIMER DRILLING  
 Address 9051 S. Mohawk St. Las Vegas, Nv.  
89118  
 Nevada contractor's license number 5962A  
 Nevada driller's license number 171  
 Signed H. V. Weimer  
 Date 11-17-76



08