WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59750
Permit No.
Basin

In Book

OWNER Bill STEEL ADDRESS 3660 Boulder Hwy L.V. NEV. 89121

2. LOCATION N.W. ¼ N.W. ¼ Sec. 31 T. 21 N/S R. 62 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SOIL		0	65	65
CEMENTED GRAVEL		65	80	15
CLAY		80	140	60
SANDY LIME		140	190	50
GRAVEL		190	230	30
CLAY		230	250	20
GRAVEL				

RECEIVED
DEC 31 1979
DIV. OF WATER RESOURCES
SOUTH OFFICE — LAS VEGAS, NEV.

Date started 3-30, 1979
Date completed 4-10, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

AIR ~~BAILER~~ TEST
G.P.M. 60 Draw down ? feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 250 feet
Casing record 8 5/8
Weight per foot 12.20 Thickness 10 GA

Diameter	From	To
8 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation TORCH
Size perforation 1/4 x 4 x AROUND
From 120 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 17 Feet below land surface
Flow G.P.M.
Water temperature °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN WATER WELL SERVICE
Address P.O. BOX 15149 L.V. NEV. 89114
Nevada contractor's license number 5095
Nevada driller's license number 40
Signed
Date 4-20-79

USE ADDITIONAL SHEETS IF NECESSARY

O-627