DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59776
Permit No.
Basin 212

1. OWNER Louis F. Evans ADDRESS 2020 Carroll St. N. L.V.

2. LOCATION S.E. ¼ N.E. ¼ Sec. 9 T. 19 N/S R. 60 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red Clay		0	25	25
Brown Clay & gravel		25	110	85
Red Clay & gravel	XX	110	185	75

RECEIVED
DEC 11 1975
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Sept. 30, 1975
Date completed Nov. 7, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 185 feet
Casing record 185' 8 5/8" O.D.
Weight per foot 12.28 lbs. Thickness 10 ga.

Diameter	From	To
8 5/8" O.D. inches	0 feet	185 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 185 feet

Perforations:
Type perforation torch
Size perforation 1/4" wide 6" long
From 85 feet to 185 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 73 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Louis F. Evans
Address 2012 Carroll St. N. L.V.
Nevada contractor's license number 3046
Nevada driller's license number 690
Signed Louis F. Evans
Date Nov. 10-1975

USE ADDITIONAL SHEETS IF NECESSARY

5471