WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

R.G.P.

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59792
Permit No.
Basin 212

1. OWNER Albert Hurtado ADDRESS 8085 Pioneer

2. LOCATION ~~NE ¼ SE~~ ¼ Sec. 10 T. 19 S N/S R. 60 E. MD B. M. Clark County
PERMIT NO. SW¼ SW¼

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	10	10
Shale Fill		10	90	80
Gravel Sand	30	90	120	30
Sand Rock		120	150	30
Shale		150	180	30
Sand water	25	180	225	25
Sandy Mud		225	300	75

RECEIVED
DEC 1 - 1977
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Nov 16, 1977
Date completed Dec 5, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
		none	

BAILER TEST
G.P.M. 15 Gal. Draw down ~~feet~~ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 300 feet
Casing record 8
Weight per foot Thickness

Diameter	From	To
inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 300 feet

Perforations:
Type perforation Rock
Size perforation ½
From 50 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 70 Feet below land surface 70
Flow 15 GL. G.P.M.
Water temperature ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sir Stafford
Address 4649 PATTERSON
Nevada contractor's license number 114-558
Nevada driller's license number 659
Signed Sir Stafford
Date Dec 12-77

USE ADDITIONAL SHEETS IF NECESSARY

5471