

WELL DRILLER'S REPORT

Please complete this form in its entirety

Log No. 59871  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 5033

PRINT OR TYPE ONLY

1. OWNER Stanley Ebeltoft ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2784 North Highland Dr.  
Las Vegas, Nevada 89030 SW SW NE 22-19-60  
1185 DEER SPRINGS WY N/S R. 60 E. Clark County \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec. 22 T. 19 N/S R. 60 E. Clark County \_\_\_\_\_  
 PERMIT NO. 125-22-601-006 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	6	6
gravel		6	8	2
white clay		8	15	7
brown clay		15	37	22
gravelly clay		37	44	7
brown clay		44	75	31
gravel		75	79	4
brown clay		79	155	76
gravel	x	155	160	5
brown clay		160	210	80
gravel	x	210	250	10
brown clay		250	280	30
gravel	x	280	300	20
brown clay		300	328	28
gravelly clay		328	350	22
brown clay		350	360	10
gravel	xxx	360	365	5
gravelly clay	xxx	365	400	35

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 400 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 8 5/8 inch to 400 ft.  
 Weight per foot \_\_\_\_\_ Thickness .188  
 Diameter From To  
12" Hole inches \_\_\_\_\_ feet 50 feet  
10" hole inches 50 feet 400 feet  
8 5/8" casing inches \_\_\_\_\_ feet 400 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 ft feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation torch cut  
 Size perforation 3/16" X 10"  
 From 180 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 DEC 12 1990  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 8-7-90 19\_\_\_\_\_  
 Date completed 8-27-90 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Bailed 40 G.P.M. from 254 ft.

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 108 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S. R. McKinney & Sons, Inc.  
 Address 1042 S. Main St. Las Vegas, Nevada  
 Nevada contractor's license number 2065  
 issued by the State Contractor's Board.  
 Nevada contractor's driller's number 45  
 issued by the Division of Water Resources.  
 Nevada driller's license number issued by the 270  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 Date 10-1-90