X

DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 59922
Permit No.
Basin

1. OWNER G. T. Prasser ADDRESS

✓ S½ - SE¼ - NE¼

2. LOCATION NW ¼ SW ¼ Sec. 22 T. 19 ~~N~~/S R. 60 E. Clark County

PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Gravel		0	6	6
Caliche		6	18	12
Caliche + Gravel		18	36	18
Red Clay + Gravel		36	43	7
Cmt. Gravel + Br. Lime		43	65	22
Clay + Gravel		65	73	8
Clay		73	233	160
Clay + Gravel		233	240	7
Gravel		240	255	15
Clay + Gravel		255	295	40
Gravel + Sand		295	383	88

RECEIVED
MAY 26 1972
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started 5-6-, 1972
Date completed 5-15-, 1972

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 383 feet
Casing record 0 - 383
Weight per foot Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	383 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 383 feet to 50' feet

Perforations:
Type perforation Cutting torch
Size perforation "OD"
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 92 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lee R. Thomas
Address 1208 Saylor Way
Nevada contractor's license number 10831
Nevada driller's license number 623
Signed Lee R. Thomas
Date 5-19-72

USE ADDITIONAL SHEETS IF NECESSARY

5471