WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 60037
Permit No.
Basin 212

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Security Housing ADDRESS 5740 N. Mustang

2. LOCATION SW ¼ SE ¼ Sec. 26 T. 19 N/S R. 60 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Clay		0	10	10
Clachl		10	30	20
Br. Lime		30	45	15
Clay + Gravel		45	250	105

RECEIVED
DEC 17 1976
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 10-12-, 1976
Date completed 10-14-, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 250 feet
Casing record 0-250
Weight per foot ..... Thickness 1090.

Diameter	From	To
8 5/8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cmt
Depth of seal Cmt. feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation Factory 8 Row's
Size perforation
From 190 feet to 250 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 115 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lee R. Thomas
Address 5965 N. Maverick
Nevada contractor's license number 10831
Nevada driller's license number 623
Signed Lee R. Thomas
Date 12-14-76

USE ADDITIONAL SHEETS IF NECESSARY

5471