DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 68072
Permit No.
Basin 212

1. OWNER J J FAIRCHILD ADDRESS 5745 N, RAINBOW

2. LOCATION SW ¼ SE ¼ Sec. 27 T. 19 N/S R. 60 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT & SAND		00	8	8
COLECHIE		8	48	40
BROWN CLAY		48	80	32
	80			
WHITE CLAY		80	120	40
LOOSE GRAVEL	120		124	4
WHITE CLAY		124	154	70
WATER	154			
		154	240	46
YELLOW CLAY		240	350	110
WATER	350			
YELLOW CLAY		350	400	050
3. H.P. BARNES	SUB.	PUMP		

Date started 8/10, 1970
Date completed 8/22, 1970

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
		10 Ft.	

RECEIVED AUG 25 1970 DIV. OF WATER RESOURCES BRANCH OFFICE LAS VEGAS, NEVADA

BAILER TEST
G.P.M. 40 Draw down feet 1/2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down 10 feet 10 hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 400 feet
Casing record
Weight per foot Thickness 10 GA.

Diameter	From	To
inches	feet	feet
8 5/8 inches	400 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 400 feet

Perforations:
Type perforation TORCH
Size perforation 1/8 X 6"
From feet to feet
From 80 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 80 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLIE CRIBBS
Address PO # 1162 CITY
Nevada contractor's license number 2018
Nevada driller's license number 70 156
Signed S B Rodgers
Date aug 22 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471