WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60108
Permit No.
Basin 222

NOTICE OF INTENT NO. 15110

1. OWNER Bunker Farms, Inc.
MAILING ADDRESS P.O. Box 7149
Bunkerville, NV 89007

ADDRESS AT WELL LOCATION
Bunkerville, NV

2. LOCATION SW ¼ NW ¼ Sec. 35 T. 13 N/S R. 70 E Clark County

PERMIT NO. 07219 (Issued by Water Resources) APN 660-640-003 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Boulders		0	40	
Sand-Clay		40	60	
Clay		60	80	
Sand		80	100	
Clay		100	120	
Sand-Clay		120	140	
Clay-Boulders				
Sand Gravel		140	180	
Clay Sand Gravel		180	240	
Clay		240	260	
Clay sand gravel		260	320	
Sand boulders				
gravel		320	380	
Clay Sand		380	400	

DCNR/DWR Received JAN 16 1997 LAS VEGAS OFFICE

Date started Nov. 6, 19 96
Date completed Dec. 24, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
15 Inches	0 Feet	400 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		0.188	+1	400

Perforations:
Type perforation Milled Slots
Size perforation 1/8 x 2 1/2 x 8 rows
From 266 feet to 340 feet
From 373 feet to 399 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 400 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 74 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the reports are true to the best of my knowledge.

Name Thompson Drilling Co. (Contractor)
Address 4185 W. Harmon (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2021
Signed Richard K. Thompson (By driller performing actual drilling on-site or contractor)
Date Jan. 10, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627