WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60151
Permit No.
Basin 210

NOTICE OF INTENT NO. 15853

1. OWNER JBR Environmental Consult
MAILING ADDRESS 5365 Mae Ann Ave Suite B2
Reno, Nevada 89523

ADDRESS AT WELL LOCATION
Alamo Nevada

2. LOCATION SE ¼ SE ¼ Sec. 27 T 11 N R 62 E Lincoln County

PERMIT NO. MO-2768 (Issued by Water Resources) | APN-08-201-02 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Lt. Brn. Silty Sand		0	1.5	1.5
Lt Brn Sandy Silt		1.5	3	1.5
Lt. Brn Silty Sand w/ Some Gravel		3	9	6
Lt. Brn Sandy Silt		9	11	2
Lt. Brn Silty Sand		11	15.5	4.5
Lt. Brn Sandy Silt		15.5	21	5.5
Lt. Brn Silty Sand		21	23.5	2.5
Lt. Brn Sandy Silty		23.5	31	7.5
Lt. Brn Silty Sand		31	34	3
Lt. Brn Sandy Silt		34	37.5	3.5
Lt. Brn Silty Sand		37.5	56	18.5
Lt Brn Sandy Gravel		56	58	2
Lt. Brn Silty Sand & Gravel		58	60	2
Lt. Brn Sandy Gravel		60	68	8
Lt. Brn Silty Sand & Gravel		68	70.5	2.5
Lt. Brn Sandy Gravel		70.5	80	9.5

Date started 12-19-, 1996
Date completed 12-19, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 80' Feet Depth Cased 80' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches	0 Feet	80' Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"			0'	65'

Perforations:
Type perforation Slotted
Size perforation .020
From 65 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal Cement Slurry
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 62 feet to 80' feet

9. WATER LEVEL
Static water level 72.5' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 4343 S. Polaris Ave (Contractor)
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2017
Signed Kenneth A. Kutania (By driller performing actual drilling on site or contractor)
Date Jan 2, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627