DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 60424
Permit No.
Basin

1. OWNER Ernest Fisher ADDRESS 5201 Westleigh Avenue
Las Vegas, Nevada 89102

2. LOCATION SW ¼ NE ¼ Sec. 32 T. 19 N/S R. 60 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel & boulders		0	35	35
sandy clay & gravel		35	140	105
lime shell		140	210	70
brown clay & gravel streaks				
	yes	210	273	63
cemented gravel		273	350	77

RECEIVED
SEP 23 1970
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started July 31, 19 70
Date completed August 14, 19 70

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 50 Draw down 168 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 350 feet
Casing record 8 5/8"
Weight per foot 12# Thickness 10guage

Diameter	From	To
8 5/8 inches	+1 feet	350 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 350 feet

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 12 4 rows
From 230 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 130' Feet below land surface
Flow G.P.M.
Water temperature cool. F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PATRICK H. THOMPSON
Address 3215 Cinder Lane-Las Vegas, Nev.
Nevada contractor's license number 4286
Nevada driller's license number 581
Signed Patrick H. Thompson
Date September 19, 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471