

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

60578

Log No. T

Rec. ....

Well No. ....

Permit No. ....

Do not fill in

Owner **Real Estate Investors (James Woods)** Driller **Effinger Drill & Pump Serv.**

Address **136 South Fourth Street** Address **5488 W. Duncan Drive** Lic. No. **212**

Location of well: <sup>NW 1/4</sup> **NE 1/4 SE 1/4** Sec. **35**, T. **19N**/S, R. **60E**, in **Clark** County  
or **Jones Blvd.**

Water will be used for **Domestic** Total depth of well **160 feet**

Size of drilled hole **12 inch** Weight of casing per linear foot .....

Thickness of casing **8 Gauge** Temp. of water .....

Diameter and length of casing **8" ID 160 feet**  
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure .....

If nonflowing well give depth of standing water from surface **55'**

If flowing well describe control works .....

(Type and size of valve, etc.)

Date of commencement of well **October 6, 1960** Date of completion of well **October 14, 1960**

Type of well rig **"71 Speed Star"**

### LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	1	1	Brown Clay
1	6	5	Gyp
6	55	49	Brown Clay & Gyp
55	58	3	Limestone (Water)
58	70	12	Brown Clay
72	74	2	Limestone (Water)
74	89	17	Red Clay
89	95	6	Limestone (Water)
95	120	25	Brown Clay
120	131	11	Decomposed Limestone (Water)
131	145	14	Clay
145	153	8	Limestone (Water)
153	160	7	Clay

Water-bearing Formation, Casing Perforations, Etc.

---

Chief aquifer (water-bearing formation)

from **120** to **131** ft.

Other aquifers..... **145-153**  
**89-95**  
**72-74**

---

First water at..... **55** feet.

Casing perforated

from **90** to **160** ft.

Size of perforations

**1/8" X 15"**



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	Remarks—Seals, Grouting, Etc.
8" ID	0	160	160	Cemented from 0 to 50 feet 2 1/2 yards of cement Pea graveled from 50 to 160 feet 4 yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

---



---



---



---



---



---

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed... Effinger Drill & Pump  
Well Driller

By... A. F. Effinger

License No. 212

Dated... October 14, ....., 19 60

(Not to be filled in by Driller)

---



---



---



---



---



---



---



---



---



---