WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60742
Permit No.
Basin 212

NOTICE OF INTENT NO. 17678

1. OWNER Sands Hotel & Casino
MAILING ADDRESS 3355 Las Vegas Blvd South Las Vegas, NV 89109
ADDRESS AT WELL LOCATION 3355 Las Vegas Blvd South, Las Vegas, NV

2. LOCATION NW ¼ SW ¼ Sec. 16 T 21 N/S R 61 E Clark County
PERMIT NO. MD-2728B (Issued by Water Resources) Parcel No. 162-16-202-008 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE CER-11
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	1½	1½
Fill		1½	5	3½
Caliche		5	8	3
partially cemented gravels		8	10½	2½
caliche		10½	11	½
sandy gravel		11	14	3
gravelly clay		14	15½	1½
gravelly clay	17.5	15½	18	2½
sandy clay		18	44½	26½
clay		44½	54	9½

Date started November 21, 1996
Date completed November 21, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 54 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	54 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	50

Perforations:
Type perforation Factory Slot
Size perforation 0.020
From 10 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-1½' / 1½-5 BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No sand
From 5 feet to 54 feet

9. WATER LEVEL
Static water level 17½ feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Contractor
Address 731 Pilot Rd Ste H
Contractor
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1869
Signed
By driller performing actual drilling on site or contractor
Date 1-17-97

RECEIVED JAN 30 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627