

faxed Jan 31, 1997
 OFFICE USE ONLY
 Log No. 60791
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15328

1. OWNER Virginia Page ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Pahrump NV 89041 Elizabeth St. Pahrump, NV 89041
 2. LOCATION SW 1/4 SE 1/4 Sec 2 T. 21 S. N/S R. 53 E E Nye County
 PERMIT NO. 44-072-27 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>decomposed Cali.</u>		<u>4</u>	<u>12</u>	<u>8</u>
<u>Light brown clay</u>	<u>X</u>	<u>12</u>	<u>90</u>	<u>78</u>
<u>Caliche</u>	<u>X</u>	<u>90</u>	<u>90</u>	<u>2</u>
<u>Brown clay</u>	<u>X</u>	<u>90</u>	<u>120</u>	<u>28</u>
<u>Caliche</u>	<u>X</u>	<u>120</u>	<u>121</u>	<u>1</u>
<u>Brown clay</u>	<u>X</u>	<u>121</u>	<u>140</u>	<u>19</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory
 Size perforation 7/8 x 4
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 50 feet

9. WATER LEVEL
 Static water level 54' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started January 18, 1997
 Date completed January 22, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>5</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry's Water Well Service Contractor
 Address P.O. Box 3392 Contractor
Pahrump NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
 Signed Larry Jenks
 By driller performing actual drilling on site or contractor
 Date January 24, 1997

