WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

faxed 1.31.97
in book

OFFICE USE ONLY
Log No. 60793
Permit No.
Basin 162

NOTICE OF INTENT NO. 15839

1. OWNER James Warner or James Robertson
MAILING ADDRESS Pahrump, NV 89041
ADDRESS AT WELL LOCATION Unit 4A Lot 33 - Block 15 Calvary St. Pahrump, NV 89041

2. LOCATION NW ¼ NE ¼ Sec. 34 T. 20 S. N/S R. 53 E. E. Nye County
PERMIT NO. Issued by Water Resources; 40.652.03 Parcel No.; Calvada Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Clay | | 0 | 6 | 6 |
| Grey Clay | | 6 | 13 | 7 |
| Calichia | | 13 | 19 | 6 |
| Brown Clay | X | 19 | 57 | 38 |
| Calichia | X | 57 | 59 | 2 |
| Brown Clay | X | 59 | 101 | 42 |
| Calichia | X | 101 | 103 | 2 |
| Brown Clay | X | 103 | 140 | 37 |

Date started January 25, 1997
Date completed January 31, 1997

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30 | 6 | 1/2 |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 140 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | 17 | .188 | 0 | 140 |

Perforations:
Type perforation Factory
Size perforation 1/4 x 4 8
From feet to feet
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 50 feet

9. WATER LEVEL
Static water level 53' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lamp Water Well Service (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board: 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1916
Signed Larry Jenkins (By driller performing actual drilling on site or contractor)
Date January 31, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627