WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1/4 Book faxed 2.1.97

OFFICE USE ONLY
Log No. 60794
Permit No.
Basin 162

NOTICE OF INTENT NO. 17785

1. OWNER Casey Moreland
MAILING ADDRESS Ridgecrest, CA
ADDRESS AT WELL LOCATION Lot #4 ON Jopya Street Pahrump, NV 89041

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 19S. N/S R. 53E E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 29.491.04 Subdivision Name Unknown

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	7	7
Decomposed CAL.		7	21	14
Calichia	X	21	60	39
Brown Clay	X	60	100	40
Grey Clay	X	100	120	20
Brown Clay	X	120	140	20

Date started ~~June 25~~ January 1, 1997
Date completed ~~June 25, 97~~ January 25, 97

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	6	1/2

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	140

Perforations:
Type perforation Factory
Size perforation 1/4 x 4"
From feet to feet
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 50 feet

9. WATER LEVEL
Static water level 54' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry's Water Well Service (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Jenkins (By driller performing actual drilling on site or contractor)
Date January 31, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627