WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60799
Permit No.
Basin 162

NOTICE OF INTENT NO. 15646

1. OWNER Stan & Mary Brathwaite
MAILING ADDRESS 101 S. Linda St
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 500 E. Blosser Ranch Rd.
Pahrump, NV 89048

2. LOCATION SW ¼ NE ¼ Sec. 34 T. 19S N/S R. 53 E. Nye County
PERMIT NO. APN#29-631-03 (Issued by Water Resources) | Parcel 8, Block B (Parcel No.) | Doc#20689 - Wm Moore Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	76	72
Clay W/small gravel		76	128	52
Brown Clay		128	142	14
Rocks and Gravel	X	142	152	10
Hard Formation (White)		152	160	8
Brown Clay		160	176	16
Hard Formation (White)		176	182	6
Brown Clay	X	182	198	16
Hard Formation		198	202	4
Brown Sticky Clay		202	248	46
Hard Formation		248	254	6
Brown Clay		254	300	46

Date started January 27, 1997
Date completed February 4, 1997

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	¼

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17#	.188	0	300

Perforations:
Type perforation Torch Cut
Size perforation ¼" width, 8" long
From 160 feet to 180 feet
From 240 feet to 260 feet
From 280 feet to 300 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 300' feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg (Contractor)
Address 1060 W. Basin Rd (Contractor)
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 7484

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed Charles Nyberg
By driller performing actual drilling on site or contractor

Date 2-5-97

DOWNDIVE Received FEB 11 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627