WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60823
Permit No.
Basin 162

NOTICE OF INTENT NO. 15501

1. OWNER Harry Drake
MAILING ADDRESS 3020 W Pittman
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3020 W. Pittman

2. LOCATION NE 1/4 SE 1/4 Sec. 1 T 20S N/S R 52E E Nye County
PERMIT NO. _____ Issued by Water Resources | 28-422-21 Parcel No. | Vegas Acres Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	11	11
Brown Calichia		11	31	20
White Clay		31	45	14
Brown Loam		45	59	14
Light Brown Loam	x	59	73	14
Brown Clay	x	73	88	15
Light Brown Popcorn	x	88	103	15
Brown Calichia	x	103	121	18
Light Brown Clay	x	121	140	19

Received FEB 10 1997

Date started 1/28/97 , 19__
Date completed 1/31/97 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation Torch
Size perforation .25 x6
From 80 feet to 100 feet
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor
Address 2301 Winery Road, Suite 2
Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025

Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 2-7-97