WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 60824
Permit No.
Basin 162

NOTICE OF INTENT NO. 14984

1. OWNER Keith Watson
MAILING ADDRESS 6220 Santovito
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
6220 Santovito

2. LOCATION NE 1/4 SE 1/4 Sec. 15 T 21S N/S. R 54E E Nye County
PERMIT NO. (Issued by Water Resources) 45-131-32 (Parcel No.) na (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	19	19
White Clay		19	38	19
Brown Calichia		38	52	14
Grey Calichia		52	75	23
Brown Popcorn		75	96	21
Brown Calichia		96	116	20
Light Brown Clay		116	141	25
Brown Clay		141	159	18
Light Grey Calichia		159	178	19
Brown Calichia		178	201	23
White Clay		201	220	19
Tan Clay	x	220	239	19
Brown Clay	x	239	256	17
Brown Calichia	x	256	275	19

SCS/DWR Received FEB 10 1997

Date started 1/31/97, 19__
Date completed 2/3/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4	Inches	0 Feet	275 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	275

Perforations:
Type perforation Torch
Size perforation .25 x 6
From 240 feet to 255 feet
From 265 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 245 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 2-7-97