WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 60840
Permit No.
Basin 212

NOTICE OF INTENT NO. 17668

1. OWNER Avis Rent-A-Car
MAILING ADDRESS 5164 Rent-A-Car Road
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION Avis Rent-A-Car
5164 Rent-A-Car Road
Las Vegas, NV 89119

2. LOCATION SE ¼ NW ¼ Sec. 27 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2522A (Issued by Water Resources) 162-27-201-005 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE SP-6
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG SP-6

Material	Water Strata	From	To	Thickness
Silty Sand with gravel		0'	8'	8'
Caliche		8'	13'	5'
Poorly Graded Sand		13'	17'	4'
Caliche		17'	21'	4'
Poorly Graded Sand		21'	23'	2'
Silty Sand with gravel		23'	27.5'	4.5'

Date started November 5, 1996
Date completed November 5, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 27.5 Feet Depth Cased 27.5 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	27.5

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	27.5

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 25 feet to 27.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-19.5' Cement, 19.5'-23' Bentonite
Placement Method: ☒ Pumped (Cement) ☒ Poured (Bentonite)
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 23 feet to 27.5 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119-4429
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on site driller M-1869
Signed (By driller performing actual drilling on site or contractor)
Date 2-10-97

Received FEB 11 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627