


OFFICE USE ONLY
 Log No. 60851
 Permit No. _____
 Basin 21a



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17668

1. OWNER: AVIS Rent-A-Car ADDRESS AT WELL LOCATION: AVIS Rent-A-Car
 MAILING ADDRESS: 5164 Rent-A-Car Road Las Vegas, NV 89119
 ADDRESS AT WELL LOCATION: 5164 Rent-A-Car Road Las Vegas, NV 89119
 2. LOCATION: SE 1/4 NW 1/4 Sec. 27 T. 21 N. R. 61 E. Clark County
 PERMIT NO. MO-2522A 162-27-201-005 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE VE-5
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG VE-5

Material	Water Strata	From	To	Thick-ness
<u>Well Graded Sand w/gravel</u>		<u>0'</u>	<u>10'</u>	<u>10'</u>
<u>Caliche</u>		<u>10'</u>	<u>11'</u>	<u>1'</u>
<u>Silty Sand with gravel</u>		<u>11'</u>	<u>12'</u>	<u>1'</u>
<u>Caliche</u>		<u>12'</u>	<u>13'</u>	<u>1'</u>
<u>Silt with sand, some gravel</u>		<u>13'</u>	<u>16'</u>	<u>3'</u>
<u>Caliche</u>		<u>16'</u>	<u>18'</u>	<u>2'</u>
<u>Silty Sand with gravel</u>		<u>18'</u>	<u>20'</u>	<u>2'</u>


8. WELL CONSTRUCTION
 Depth Drilled: 20 Feet Depth Cased: 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 20
8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>1.9</u>	<u>0.237</u>	<u>0</u>	<u>20</u>

Perforations:
 Type perforation Factory Slot
 Size perforation 0.020"
 From 10 feet to 20 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal: 20' Concrete
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 7.5 feet to 20 feet
 Scal Type:
 Neat Cement
 Cement Grout
 Concrete Grout



Date started November 6, 1996
 Date completed November 6, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level: _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name: Thomas High
 Address: 731 Pilot Road, Suite H
Las Vegas, NV 89119-4429
 Nevada contractor's license number issued by the State Contractor's Board: _____
 Nevada driller's license number issued by the Division of Water Resources: M-1869
 Signed: _____
 By driller performing actual drilling on site or contractor
 Date: 2/10/97