WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

In Book

OFFICE USE ONLY
Log No. 60892
Permit No.
Basin 230

1. OWNER Floyd or Brenda MEDLOCK ADDRESS Lathrop Wells, NV 89020

2. LOCATION Lot 7 SE 1/4 SW ¼ NW ¼ Sec. 12 T. 17 N/S R. 48 E. MDB&M NYE County
PERMIT NO. Domestic NA

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	6	6
CEMENTED LIME		6	29	23
SAND				
WHITE LIME		29	35	6
HARD CEMENTED		35	42	7
LIME				
BROWN CLAY		42	46	4
MED. HARD LIME		46	60	14
HARD-LIME	10	60	70	10
GRAY CLAY		70	82	12
HARD LIME		82	86	4
GREENISH CLAY		86	92	6
GRAY CLAY		92	95	3
" "		95	135	40
WHITE CLAY		135	137	2
GREEN CLAY SED.		137	156	19
LIGHT GRAY CLAY		156	200	44

RECEIVED
MAY 3 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev

Date started October 23, 19 78
Date completed 3-10, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
SUB.	15 EPM	63'	4 HRS.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 200 feet
Casing record 8" 200'
Weight per foot 16.94 Thickness .188

Diameter	From	To
12 inches	0 feet	50 feet
10 1/2 inches	50 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 4 X 1/4 inch
From 60 feet to 70 feet
From 180 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 57' Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DONALD G. TRENARY
Address BOX 616B STAR RT. 15 LATHROP WELLS NV. 89020
Nevada contractor's license number 14214 C-D Company by Boyd
Nevada driller's license number 971
Signed Donald G. Trenary
Date April 10, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471