WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 60902 In Book
Permit No.
Basin 230

1. OWNER Robert J or Eva Fishel ADDRESS Star Rt 15 Box 533R Lathrop Wells, NV 89020

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 17S N/S R. 49 E. MDBM NYE County
PERMIT NO. 2½ acre ± Portion

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	4	4
SANDY GRAVEL		4	8	4
SANDY BRN. CLAY		8	34	26
HARD GRAY CEMENTED SAND		34	44	10
SANDY CLAY SM. GRAVEL		44	55	11
HARD CEMENTED SAND		55	65	10
BRN. CLAY		65	78	13
COURSE SAND GRAVEL TO 1/4"	12	78	90	12
HARD CEMENTED SAND		90	95	5
BRN. CLAY SANDY		95	115	20
SAND & GRAVEL TO 1"	7	115	122	7
SANDY BRN. CLAY		122	126	4
GRAVEL & SAND TO 1"		126	135	9
BRN. CLAY		135	149	14
CEMENTED SAND		149	151	2
GRAVEL TO 1"	9	151	160	9
SANDY CLAY		160	164	4
SAND GRAVEL TO 1"	16	164	180	16
BRN. CLAY		180	184	4
SAND GRAVEL TO 1"	10	184	194	10
BRN. CLAY		194	200	6

Date started July 11, 19 79
Date completed July 28, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
SUB	30	2'	2

RECEIVED AUG 20 1979 Div. of Water Resources Branch Office — Las Vegas, Nev.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 200 feet
Casing record 201' - 6" OF 8"
Weight per foot 16.94 Thickness .188

Diameter	From	To
12 inches	0 feet	60 feet
9 1/2 inches	60 feet	201 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 194 feet

Perforations:
Type perforation TORCH CUT
Size perforation 4 x 1/4"
From 70 feet to 198 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 66' Feet below land surface 66
Flow ..... G.P.M.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DON G TRENARY
Address LATHROP WELL NV
Nevada contractor's license number 14214 C-D Co ~~D. Boyd~~
Nevada driller's license number 971
Signed Don G. Trenary
Date Aug 6 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed B & B Drilling Co Inc
Well Driller

By Ronald Bradshaw

License No. 173

....., 19.....

OFFICE
STATE ENGINEER

1955 AUG 3 AM 9 30

(Not to be filled in by Driller)