RECEIVED
DIVISION OF WATER RESOURCES
FEB 21 1968
OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 60905
Permit No.
Basin 230

1. OWNER J. C. Stedman ADDRESS P.O. Box 284 Tulare, Calif

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 17 N/S R. 49 E. NYE County
PERMIT NO. To be filed on at a later date when completely tested

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface, Sandy Loam		0	34	34
Sand		34	37	3
Cemented Sand		37	39	2
Sand	Yes	39	44	5
Cemented Sand		44	45	1
Sand	Yes	45	48	3
Hard Sand		48	50	2
Clay, Brown		50	52	2
Hard Sand		52	53	1
Fine Sand	Yes	53	57	4
Cemented Sand		57	60	3
Fine Sand	Yes	60	68	8
Limy Sandstone		68	80	12
Clay		80	81	1
Sandy Clay	Yes	81	90	9
Brown Clay with		90		
white pebbles			93	3
Sandy Brown Clay		93	95	2
Brown Clay		95	181	86

Date started Sept 15 1967, 19
Date completed Feb 15 1968, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No Complete Test Due To unusual amount of Fine sand which will require much pumping to develope.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 15" shoe inches Total depth 181 feet
Casing record 182' of 12"
Weight per foot 26 Thickness .235

Diameter	From	To
12" (12¾ O.D.) inches	+1 feet	181 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation 6 Rows ¼" x 12" Field Cut
Size perforation
From 43 feet to 99 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 42' Feet below land surface
Flow — G.P.M. —
Water temperature 73 ° F. Quality Good.

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Michael G. Gilgan
Address P.O. Box 252 Lathrop Wells
Nevada contractor's license number
Nevada driller's license number 512
Signed Michael G. Gilgan
Date Feb 16, 1968

USE ADDITIONAL SHEETS IF NECESSARY

5471