

OFFICE USE ONLY
 Log No. 60955
 Permit No. _____
 Basin _____

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9053

1. OWNER Everett Anderson ADDRESS AT WELL LOCATION Laughlin
 MAILING ADDRESS _____

2. LOCATION SE 1/4 SW 1/4 Sec. 1 T 21s N/S R. 53 E Nye County
 PERMIT NO. N/A 44-102-04 Manco Sub. Lot 193
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	7'	7'
caliche		7'	9'	2'
clay		9'	12'	3'
caliche		12'	14'	2'
clay		14'	26'	12'
caliche		26'	28'	2'
clay		28'	58'	30'
caliche	WB	58'	60'	2'
clay		60'	65'	5'
caliche	WB	65'	68'	3'
clay		68'	77'	9'
caliche	WB	77'	81'	4'
clay		81'	92'	11'
caliche	WB	92'	95'	3'
clay		95'	119'	24'
caliche	WB	119'	123'	4'
clay		123'	132'	9'
caliche	WB	132'	138'	6'
clay		138'	140'	2'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140 feet
 _____ inches
 _____ inches
 Casing record 140 x 8 5/8
 Weight per foot 16.94 Thickness .188

Diameter	From	To
<u>8 5/8</u> inches	<u>0'</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140' feet to 50' feet

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 INCH BY 3 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet

RECEIVED

JAN 30 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 1-24, 1991
 Date completed 1-27, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 P.M. _____ Draw down _____ feet _____ hours
 Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 50 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling
Contractor
 Address HCR 65 Box 80358 Pahrump, Nv. 89041
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
By driller performing actual drilling on site or contractor
 Date 1-28-91