WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61006
Permit No.
Basin

1. OWNER David R Jennings ADDRESS Pahrump E. D.

2. LOCATION N W ¼ N E ¼ Sec. 1 T. 21 S N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Pepcorn Shale		5	15	10
Grey Clay		15	45	30
Brown Clay		45	100	55
Red Clay		100	120	20
Hard Shell		120	125	5
Brown Clay		125	200	75

RECEIVED
DEC 2 1980
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 11-7-, 1980
Date completed 11-9-, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 200 feet
Casing record 8 5/8 X 200'
Weight per foot 14.55 Thickness 156

Diameter	From	To
8 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Torch
Size perforation 1/8 X 12"
From 100 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface 30
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name C B Capehart
Address 4425 Stacey Ave L.V.
Nevada contractor's license number 016521
Nevada driller's license number 1081
Signed C B Capehart
Date 11-27-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627