



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER William Carsten ADDRESS Primm Nevada

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 19 S. R. 52 E. Map County \_\_\_\_\_  
PERMIT NO. \_\_\_\_\_

|   |  |   |
|---|--|---|
| 3. TYPE OF WORK   | 4. PROPOSED USE  | 5. TYPE WELL  |
| New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> | Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> | Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> |
| Deepen <input type="checkbox"/> Other <input type="checkbox"/>                    | Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>          | Other <input type="checkbox"/>  |

6. LITHOLOGIC LOG

| Material                    | Water Strata | From       | To         | Thick-ness |
|-----------------------------|--------------|------------|------------|------------|
| <u>surface</u>              |              | <u>0</u>   | <u>3</u>   | <u>3</u>   |
| <u>white clay formation</u> |              | <u>3</u>   | <u>32</u>  | <u>29</u>  |
| <u>soft brown clay</u>      | X            | <u>32</u>  | <u>52</u>  | <u>20</u>  |
| <u>white clay</u>           | X            | <u>52</u>  | <u>105</u> | <u>53</u>  |
| <u>brown clay</u>           |              | <u>105</u> | <u>140</u> | <u>35</u>  |

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 140 feet  
 Casing record 0-140 ft  
 Weight per foot 12 lbs Thickness 10 gauge

| Diameter        | From     | To              |
|-----------------|----------|-----------------|
| <u>8</u> inches | <u>0</u> | <u>140</u> feet |
| _____ inches    | _____    | _____ feet      |
| _____ inches    | _____    | _____ feet      |
| _____ inches    | _____    | _____ feet      |
| _____ inches    | _____    | _____ feet      |
| _____ inches    | _____    | _____ feet      |

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation hard cut  
 Size perforation 3/8" wide 8" long  
 From 60 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED

AUG 26 1977

Div. of Water Resources  
Branch Office - Las Vegas, Nev.

Date started 6-18, 1977  
Date completed 6-19, 1977

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| _____    | _____  | _____     | _____            |
| _____    | _____  | _____     | _____            |
| _____    | _____  | _____     | _____            |

BAILER TEST

G.P.M. 20 Draw down 0 feet 0 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 34 feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature Cool F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nylund Well Drilling  
 Address Primm Nevada 89041  
 Nevada contractor's license number 7484  
 Nevada driller's license number 725  
 Signed Charles Nylund  
 Date 8-11-77