WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61052
Permit No.
Basin
NOTICE OF INTENT NO. 14640

1. OWNER hester Smith
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4220 Jackie

2. LOCATION NW ¼ NW ¼ Sec. 1 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-122-04 (Parcel No.) Moorehead Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	9	5
Calichie		9	16	7
Clay		18	25	7
Calichie		25	28	3
Clay		28	36	8
Calichie		36	39	3
Clay		39	47	8
Calichie		47	49	2
Clay		49	52	3
Calichie	WB	52	55	3
Clay		55	65	10
Calichie	WB	65	68	3
Clay		68	77	9
Calichie	WB	77	81	4
Clay		81	102	21
Calichie	WB	102	108	6
Clay		108	114	6
Calichie	WB	114	119	5
Clay		119	125	6
Calichie	WB	125	128	3
Clay		128	137	9
Calichie	WB	137	140	3

RECEIVED
MAY 10 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started April 28, 19 95
Date completed May, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 1/4	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 5/5/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627