WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61053
Permit No.
Basin

NOTICE OF INTENT NO. 14637

1. OWNER Lester Smith
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4400 S. Jackie

2. LOCATION SW ¼ NW ¼ Sec. 1 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-122-06 (Parcel No.) Moorehead Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	13	9
Calichie		13	16	3
Clay		16	25	9
Calichie		25	27	2
Clay		27	36	9
Calichie		36	39	3
Clay		39	51	12
Calichie	WB	51	54	3
Clay		54	61	7
Calichie	WB	61	63	2
Clay		63	74	11
Calichie	WB	74	77	3
Clay		77	88	10
Calichie	WB	88	90	2
Clay		90	94	4
Calichie	WB	94	97	3
Clay		97	105	8
Calichie	WB	105	107	2
Clay		107	111	4
Calichie	WB	111	113	2
Clay		113	117	4
Calichie	WB	117	120	3
Clay		120	135	15
Calichie	WB	135	140	5

MAY 16 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started April 28, 1995
Date completed May 4, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 5/5/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627