WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61098
Permit No.
Basin

NOTICE OF INTENT NO. 14642

1. OWNER Glynn Durnen
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1920 Pluto

2. LOCATION SE ¼ NE ¼ Sec. 2 T. 21 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-173-19 (Parcel No.) Gamebird (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	5	3
Clay		5	10	5
Calichie		10	12	2
Clay		12	16	4
Calichie		16	21	5
Clay		21	32	11
Calichie		32	37	5
Clay		37	44	7
Calichie		44	46	2
Clay		46	51	5
Calichie	WB	51	60	9
Clay		60	66	6
Calichie	WB	66	68	2
Clay		68	86	18
Calichie	WB	86	89	3
Clay		89	98	9
Calichie	WB	98	103	5
Clay		103	117	14
Calichie	WB	117	119	2
Clay		119	124	5
Calichie	WB	124	126	2
Clay		126	135	9
Calichie	WB	135	138	3
Clay		138	140	2

RECEIVED
MAY 16 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 4, 1995
Date completed May 4, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 5/5/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627