WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61110
Permit No.
Basin 162

In Book

(Bill Moon)

1. OWNER Glenn Woodworth ADDRESS Pahrump Leslie Rd.

2. LOCATION S-E ¼ S-E ¼ Sec. 30 T. 19 N/S R. 52 E. M.D.M. County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0'	1'	1'
Sandy clay		1'	5'	4'
white agglomerated clay		5'	16'	11'
Sandy clay		16'	34'	18'
Bentonite		34'	39'	5'
Clay		39'	40'	1'
Sandy clay		40'	48'	8'
Caliche		48'	50'	2'
Sandy clay		50'	75'	25'
Clay / caliche stx.		75'	90'	15'
Bentonite		90'	95'	5'
Sandy clay		95'	105'	10'
Sand		105'	106'	1'
Clay / sand stx.		106'	108'	2'
Sandy clay		108'	130'	22'
Caliche		130'	132'	2'
Sandy clay		132'	140'	8'

RECEIVED
JUN 30 1978
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 28 Draw down 12 feet 1 hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 140 feet
Casing record
Weight per foot 12.15 Thickness 10 R.

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation torch cut
Size perforation ¼" x 12" 2 rounds
From 100 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 18 Feet below land surface 18
Flow G.P.M.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne L. Floyd Pump & Drilling
Address P.O. Box 32 A Pahrump
Nevada contractor's license number 12344
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 6-27-78

USE ADDITIONAL SHEETS IF NECESSARY

5471