WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

[redacted] # 0562

OFFICE USE ONLY
Log No. 61127
Permit No.
Basin

1. OWNER EARL JONES ADDRESS 3800 SOUTH DECATUR, LAS VEGAS, NV

2. LOCATION SW ¼ SE ¼ Sec. 2 T. 21S N/S R. 53 E. NYE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	4	4
BROWN CLAY		4	36	32
LIGHT BROWN CLAY		36	66	30
WHITE CLAY	X	66	96	30
BROWN CLAY	X	96	140	44

RECEIVED
APR 21 1982
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started APRIL 3, 19 82
Date completed APRIL 5, 19 82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 3 feet 1/4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 140 feet
Casing record 8" CASING
Weight per foot 15# Thickness .156

Diameter	From	To
8" inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8"W X 8"L
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 36 Feet below land surface 35
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES NYBERG
Address STAR ROUTE 5231, PAHRUMP, NV 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 4/17/82

USE ADDITIONAL SHEETS IF NECESSARY

O-627