WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61194
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8778

1. OWNER Fred Spicce
MAILING ADDRESS
ADDRESS AT WELL LOCATION Pluto Street

2. LOCATION SW ¼ NW ¼ Sec. 2 T. 21s N/S R. 53 E. NYE County
PERMIT NO. N/A (Issued by Water Resources) 44-164-16 (Parcel No.) Lot 7 block 7 gamebird Subdivision (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	3'	3'
calichie		3'	5'	2'
clay		5'	16'	11'
calichie		16'	18'	2'
clay		18'	25'	7'
calichie		25'	28'	3'
clay		28'	30'	2'
calichie		30'	33'	3'
clay		33'	42'	9'
calichie		42'	45'	3'
clay		45'	54'	9'
calichie	WB	54'	57'	3'
clay		57'	61'	4'
calichie	WB	61'	63'	2'
clay		63'	74'	11'
calichie	WB	74'	76'	2'
clay		76'	81'	5'
calichie	WB	81'	83'	2'
clay		83'	88'	5'
calichie	WB	88'	91'	3'
clay		91'	121'	30'
calichie	WB	121'	123'	2'
clay		123'	128'	5'
calichie	WB	128'	130'	2'
clay		130'	132'	2'
calichie	WB	132'	135'	3'
clay		135'	140'	5'

Date started 10-22, 1990
Date completed 10-26, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
NOV 21 1990
Div. of Water Resources
Branch Office Las Vegas, Nv

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140' feet
..... inches
..... inches
Casing record 140' x 8 5/8"
Weight per foot 16.94 Thickness .188

Diameter	From	To
8 5/8" inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation factory sawcut
Size perforation 1/8" x 3"
From 140 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 50 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 65 box 80358 Pahrump, Nv 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Donnie Brown (By driller performing actual drilling on site or contractor)
Date 11-16-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627