WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61232
Permit No.
Basin 103

NOTICE OF INTENT NO. 49307

OWNER Samuel Morgan
MAILING ADDRESS 4367 Rio Vista Rd Carson City NV 89702
ADDRESS AT WELL LOCATION 4367 Rio Vista Rd Carson City NV 89702

2. LOCATION SE ¼ NE ¼ Sec. 2 T 14 N/S R 20 E Carson County
PERMIT NO. (Issued by Water Resources) Parcel No. 10-503-31 Subdivision Name Mexican Dam

3. WORK PERFORMED: ☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☑ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sands		0	15	15
Course DG Sands		15	75	60
Brown Clay (Sandy)		75	130	
Hard DG Sands		130	198	
w/ Lot of Clay Seems				24
Brown Clay (Hard DG)		198	265	
Hard Granite		265	327	
Broken Fracture Rusty Color		327	336	
Hard Granite Clay		336	349	
Broken Fractures		350	370	

Date started 4-2, 1995
Date completed 4-9, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 370 Feet Depth Cased 370 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	50 Feet
9⅞ Inches	60 Feet	370 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	370

Perforations:
Type perforation Mill Slot
Size perforation 3 x 7/32
From 330 feet to 370 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 370 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A-1 Pump Company (Contractor)
Address 555 Hwy 50 E #3 Carson City NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L. Hack (By driller performing actual drilling on site or contractor)
Date 4-9-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627