

OFFICE USE ONLY
 Log No. 61235
 Permit No. _____
 Basin C89

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28058

1. OWNER Billie Kirschner ADDRESS AT WELL LOCATION 3575 Lyon Ln. New Washoe City NV 89704
 MAILING ADDRESS 3575 Lyon Ln. New Washoe City NV 89704
 2. LOCATION NW 1/4 SE 1/4 Sec. 6 T. 16 S R. 20 E Washoe County
 PERMIT NO. 050-401-09 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	6	6
Brown Sands and Hard Peck Clay		6	14	8
Brown Dk Sands		14	75	61
Gray Clay		75	90	15
Silty Sands		90	110	20
Coarse Dk Sands		110	150	40

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10/4 Inches To 0 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 130 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55 feet to 150 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A. H. Pump Co. Contractor
 Address 5551 Hwy 50 E # 3 Carson City NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael H. Beck
 By driller performing actual drilling on site or contractor
 Date 10-16-96

Date started 10-14 1996
 Date completed 10-16 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED
 06 OCT 16 PM 4:52
 STATE ENGINEERS OFFICE