

OFFICE USE ONLY  
 Log No. 61259  
 Permit No. \_\_\_\_\_  
 Basin 102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28059

1. OWNER Dave & Mary Ann Shultz ADDRESS AT WELL LOCATION 7840 Winchester Silver Springs NV.  
 MAILING ADDRESS 21165 Lakeshore DR. Carson City NV. 89709  
 2. LOCATION NW 1/4 SW 1/4 Sec. 16 T. 17 S. R. 25 E. Lyon County  
 PERMIT NO. 17-291-13 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Soft Sands</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Coarse Sands and Gravels</u>		<u>6</u>	<u>87</u>	<u>81</u>
<u>Brown Clay</u>		<u>87</u>	<u>103</u>	<u>16</u>
<u>Gray Clay</u>		<u>103</u>	<u>115</u>	<u>12</u>
<u>Coarse Sands</u>		<u>115</u>	<u>125</u>	<u>10</u>
<u>Soft Coarse Sands and Gravels</u>	<u>XXX</u>	<u>125</u>	<u>150</u>	<u>25</u>

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 1/4 Inches To 0 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:  
 Type perforation M.I. slot  
 Size perforation 3 1/2 x 3/32  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 150 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Hi H Pump Company Contractor  
 Address 5551 Hwy 50 E. #3 Contractor  
Carson City NV. 89701  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Mildred Beck  
 By driller performing actual drilling on site or contractor  
 Date 10-7-96

Date started 10-5, 1996  
 Date completed 10-6, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED  
 96 OCT 16 PM 4:52  
 STATE ENGINEERS OFFICE