

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 61262
Permit No. _____
Basin. 054

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28060

1. OWNER Melody Mixon ADDRESS AT WELL LOCATION 16275 Mt Rose Hwy Reno NV 89510
MAILING ADDRESS 19651 Holiday Rd. Miami FL 33157
2. LOCATION S60 1/4 SE 1/4 Sec 34 T 18 S R 19 E Washoe County
PERMIT NO. NW 049-070-32 Parcel No. _____ Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders w/ clay seams		1	25	25
Boulders with loose sand and clay stringers		25	130	105
Coarse Dt Sands and Boulders		130	190	60
Quartz and Dt Sands carrying water	xxx	190	220	30

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
From 10 1/4 Inches 0 Feet 220 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 180 feet to 220 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 55 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 55 feet to 220 feet

RECEIVED
96 OCT 16 PM 4:52
STATE ENGINEERS OFFICE

N 39.379337
W 119.833426 NAD27
Deeper under NDS 57632

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow _____ G.P.M. 20+ P.S.I.
Water temperature Cold °F Quality Good

Date started 10-7 19 96
Date completed 10-10 19 96

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge

Name As H Pump Co. Contractor
Address 5551 Hwy 50 E #3 Carson City NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources 1905
Signed Michael D. Beck By driller performing actual drilling on site or contractor
Date 10-10-96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>45</u>	<u>3 HRS</u>