WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61272
Permit No.
Basin

#0837 in Book

1. OWNER Roy Beatie ADDRESS

2. LOCATION NE ¼ NE ¼ Sec. 10 T. 21 S N/S R. 53 E Nye County
PERMIT NO. Domestic

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
tan, white, gray clay		0	15	15
tan, gray clay w/calif		15	30	15
tan, white clay		30	45	15
tan clay		45	60	15
tan clay		60	75	15
tan clay		75	90	15
tan clay		90	105	15
tan clay w/calif		105	120	15
tan clay w/calif		120	140	20

RECEIVED DEC 9 1982 Div. of Water Resources Branch Office—Las Vegas, Nev.

Date started Nov 29, 1982
Date completed Dec 2, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. N/A Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 140 feet
Casing record 8 5/8
Weight per foot Thickness 188 wall

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation torch
Size perforation ¼" by 12"
From 140 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 38' Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name John Floyd
Address P.O. Box 392, Pahrump
Nevada contractor's license number 19268
Nevada driller's license number 588
Signed John C. Floyd
Date 12-6-82

USE ADDITIONAL SHEETS IF NECESSARY

O-627