WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61278
Permit No.
Basin

In Book 1 #0932

1. OWNER Ken Gager ADDRESS Pahrump Nevada 89041

2. LOCATION SE ¼ SE ¼ Sec. 10 T. 21-S N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface		0	4	4
white clay		4	28	24
brown clay		28	45	17
white clay	x	45	70	25
calciche	x	70	78	8
brown clay	x	78	140	62

RECEIVED
MAR 14 1983
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started Jan 20, 19 83
Date completed Jan. 22, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 gals Draw down 4 feet 1/4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 140 feet
Casing record 140 ft. of 8 in. casing
Weight per foot 15 lbs Thickness .156

Diameter	From	To
8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation torch cut
Size perforation 3/8 inch width 8 inch long
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 45 Feet below land surface 44
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg
Address St. Rt. Box 5231
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date March 10, 1983

USE ADDITIONAL SHEETS IF NECESSARY

O-627