WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 61279
Permit No.
Basin
NOTICE OF INTENT NO. 1747

1. OWNER Betty Gater
MAILING ADDRESS Pahrump, Nev. 89041
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NE ¼ Sec. 10 T. 21-S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Caliche Formation | | 4 | 26 | 22 |
| Gray Clay | | 26 | 48 | 22 |
| Brown Clay | x | 48 | 60 | 12 |
| Soft White Clay | x | 60 | 92 | 32 |
| Brown Clay | x | 92 | 128 | 36 |
| White Clay | x | 128 | 132 | 4 |
| Hard Lime | | 132 | 138 | 6 |
| White Clay | x | 138 | 140 | 2 |

RECEIVED
OCT 4 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started August 31, 19 84
Date completed August 31, 19 84

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 20 gals. Draw down 4 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 140 feet
Casing record 140 ft. of 8 in casing
Weight per foot 15 lbs. Thickness .156

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 140 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch cut
Size perforation 3/8 in width 8 in long
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address St Rt Box 36525 (Contractor)
Nevada contractor's license number 7484
Nevada contractor's drillers number
Nevada driller's license number 725 (Actual Driller)
Signed Charles Nyberg (Contractor)
Date Oct 2, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434