WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61341
Permit No.
Basin 162

1 in 13 book

1. OWNER Wayne Alverson ADDRESS Country Place #2 Pahrump

2. LOCATION W W ¼ S E ¼ Sec. 15 T. 19 N/S R. 53 E. Nye County
PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☒ Recondition ☐	Domestic ☒ Irrigation ☐ Test ☐	Cable ☐ Rotary ☒
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Brown Clay		4	30	26
Sand & Gravel		26	55	29
Coarse Gravel		55		
Mixed W/Clay			110	55
Brown Clay		110	133	23
Gray Sandy	✓	133		
Clay. Some small			168	27
gravel				

RECEIVED
AUG 1 1979
Div. of Water Resources
Eng. Office—Las Vegas, Nev.

Date started 5-19-, 1979
Date completed 5-30, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 160 feet
Casing record 160
Weight per foot 12 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cmt.
Depth of seal 53 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 53 feet to 160 feet

Perforations:
Type perforation Torch
Size perforation .125
From 100 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 101 Feet below land surface 101
Flow G.P.M.
Water temperature Cool ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name C. B. Capehart
Address 4425 Stacey Ave
Nevada contractor's license number
Nevada driller's license number 1081
Signed C. B. Capehart
Date 6-15-79

USE ADDITIONAL SHEETS IF NECESSARY

5471