



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13180

1. OWNER John Cunnius ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NW 1/4 Sec. 15 T. 19-S N/S R. 53 E. Nye County _____
 PERMIT NO. APN 29-232-02 Issued by Water Resources Parcel No. 7 Block 10 Country Place II Unit I Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	20	20
Large Rocks & Gravel		20	28	8
Sandy Clay		28	42	14
Sand & Gravel		42	48	6
Brown Clay		48	72	24
Large Rocks & Gravel		72	82	10
Brown Clay		82	132	50
Sand/Gravel Lg Rock	X	132	140	8
Brown Clay		140	162	22
LG Rocks & Gravel		162	175	13
Brown Clay		175	194	19
Cemented Gravel		194	200	6

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches 0 Feet To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	18lbs.	.188	0	200

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4" width 8" long
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

RECEIVED
 MAY 09 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 118 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started April 27, 1995
 Date completed May 1, 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
20	4	1/4	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address HCR 77 BOX 36525 Pahrump, NV Contractor
 Nevada contractor's license number 7484 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date 5/3/95