

OFFICE USE ONLY
 Log No. 61375
 Permit No. _____
 Basin. 084

I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31.567

1. OWNER Leslie Guidera ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1125 Dodson Way 5855 Peak Road
Sparks Nevada 89510 Reno Nevada 89510

2. LOCATION SE 1/4 SE 1/4 Sec 35 T 23 N S R 20 EAST WASHOE County
 PERMIT NO. 65500 076-110-013 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown fine sand		0	12	
Multi colored gravels		12	30	
Multi colored gravels & brown clay		30	65	
Multi colored small gravels		65	70	
Weathered white & black granite		70	90	
Multi colored gravels & fine brown sand	x	90	200	
Small gravels white with a little black decomposed granite	x	200	231	
T.D. 231'				

8. WELL CONSTRUCTION

Depth Drilled 231 Feet Depth Cased 231 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>1.2-3/4</u> Inches	<u>0</u> Feet <u>231</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8-5/8</u>	<u>16.94</u>	<u>.188</u>	<u>-1 1/2</u>	<u>231</u>

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 x 3
 From 171 feet to 211 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 231 feet to 50 feet

9. WATER LEVEL

Static water level 100' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. Contractor
 Address 1800 1/2 Frazer Avenue Contractor
Sparks, NV 89431

Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1

Signed Larry Welch
 By driller performing actual drilling on site or contractor
 Date Oct 18, 1996

Date started October 01, 1996
 Date completed October 04, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>3-1/2</u>

RECEIVED
 30 OCT - 9 AM 11:56
 WATER ENGINEERS OFFICE