

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 61417  
 Permit No. \_\_\_\_\_  
 Basin. 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17671  
 ADDRESS AT WELL LOCATION MAIN STREET STATION

1. OWNER UPRR C/O USPCA LAIDLAW ADDRESS AT WELL LOCATION MAIN STREET STATION  
 MAILING ADDRESS 5665 FLATIRON PKWY  
BOULDER, CO 80301  
 2. LOCATION SW 1/4 SE 1/4 Sec. 27 T. 20 N. R. 61 E. CLARK County  
 PERMIT NO. MO-2587A Parcel No. 139-27-402-008 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE VMW-59  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>FILL</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>SILT</u>		<u>6</u>	<u>11</u>	<u>5</u>
<u>CALICHE</u>		<u>11</u>	<u>18</u>	<u>7</u>
<u>SILT - PARTIALLY CMT</u>		<u>18</u>	<u>19</u>	<u>1</u>
<u>CALICHE</u>		<u>19</u>	<u>20</u>	<u>1</u>
<u>SILT</u>		<u>20</u>	<u>30</u>	<u>10</u>

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>30</u>

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.010  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-4' / 4-8' BENTONITE  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8 feet to 30 feet

9. WATER LEVEL  
 Static water level 15.85 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started NOVEMBER 8, 1996  
 Date completed NOVEMBER 8, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DON WILSON Contractor  
 Address 731 PILOT RD STE H  
LAS VEGAS NV 89119 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 2-11-97