DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61433
Permit No.
Basin

1. OWNER TRUMAN DOUGLAS ADDRESS LAS VEGAS, NEV.

2. LOCATION SE ¼ SW ¼ Sec. 11 T. 21-S N/S R. 53 E. NYE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	3	3
CALICHE Formation		3	26	23
WHITE CLAY		26	54	28
CALICHE	X	54	59	5
WHITE CLAY	X	59	80	21
TOUGH WHITE CLAY		80	98	18
WHITE CLAY	X	98	120	22
SOFT Formation	X	120	124	4
TOUGH WHITE Formation		124	130	6

RECEIVED
OCT 22 1971
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started SEPT 17, 19 71
Date completed SEPT 23, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 4 feet 0 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 130 feet
Casing record 130' 8" CASING
Weight per foot 15 LBS Thickness .155

Diameter	From	To
8 inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" WIDE 8" LONG
From 80 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 44 Feet below land surface 44
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES NYBERG
Address R.R. BAKERSFIELD CALIF.
Nevada contractor's license number 7484
Nevada driller's license number 418
Signed Charles Nyberg
Date Sept 28, 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471